

## **CORRIGENDUM-01**

TENDER NO: IUAC/NIT/17/UGN/2016-17

Name of Work: SITC of LT Panels, Cables & Terminations (Electrical Power & Lighting works) for  
BH-III

The following clarifications are made to the tender no: TENDER NO: IUAC/NIT/17/UGN/2016-17.  
Kindly take note of these clarifications before submitting price bid.

**At Page # 2 :**

**General Terms and Conditions: Clause: 2 (i)**

- 1) Three similar works of value of Rs. 18.0 lakhs & above  
OR
- 2) two similar works of value of Rs. 27.0 lakhs & above  
OR
- 3) one similar work of value of Rs. 36.0 lakhs & above

**may be read as**

- 1) Three similar works **each** of value not less than 18.0 lakhs  
OR
- 2) Two similar works **each** of value not less than 23.0 lakhs  
OR
- 3) one similar work of value not less than 36.0lakhs

**Similar Works means Supply , Installation, Testing and Commissioning of LT Panels and cables**

**(At Page # 7 :**

**Annexure-II, Clause: 3.1, Clause:3.2, Clause:3.3 and Clause:3.4** (Item No-1.1, 1.2, 1.3, and 1.4, of schedule of prices)

- i). 35 kA, 4 pole electrically operated fixed type ACB's with microprocessor release of O/L, S/C & E/F may be read as **50 KA breaking capacity, 4 pole EDO type ACB's with microprocessor release of O/L, S/C, instantaneous over current & E/F.**
- ii). 35 kA, MCCB's with magneto-thermal release with electronic trip may be read as **Handle operated MCCB's with Thermal Magnetic type with 36 kA Breaking capacity.**

**At Page # 10 :**

**Annexure-III, Clause :4.1.3**

- i) **Al. bus bars shall be applicable for panels under :-**  
Clause:3.1, Clause:3.2, Clause:3.3 and Clause:3.4, Clause:3.8, Clause:3.9 and Clause:3.10 of Annexure-II (Item No-1.1, 1.2, 1.3, 1.4, 1.8, 1.9 and 1.10of schedule of prices)

The other contents remain unchanged.

A.O (S&P)  
Inter-University Accelerator Centre  
Aruna Asaf Ali Marg  
New Delhi – 110 067